

Annexure C

Appendix-XIII

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. CMO/4159

Dated:

It is certified that an inspection team headed by Dr. Rohit Goel, Dip.CMO, Pub. Health
(Name of Officers with designation) from expert from CMO office PHED
(Name of Department/ Office) inspected the Yash Global School, Sabalpur, Pilsawa
(Name & Address of the school) on 18/04/24 (date of inspection), checked the water test report submitted by the school and found that the school has potable drinking water for students and staff of the institution and is having provision for running water in the toilets and maintaining hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of 31/03/2026

Signature with Seal Rohit Goel
मुख्य चिकित्सा अधिकारी

Name : Dr. Rohit Goel
अज्ञात

Designation : Pub. Health exp./Dip. CMO

Assistant Engineer of
the Govt. Public Health Department (PHED)/
Authorised officer of the Local Body

Name & Address of the Office / Department :

CMO office aligarh.

To

Yash Global School
Sabalpur, Pilsawa

(Name & Address of the Institution)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.



District Level Water Analysis Laboratory Aligarh
Address: First Floor office of Superintending Engineer, U.P. Jal Nigam (Rural)
Aligarh-202001

TC9891

Water Test Report

Report No.	ALI/ILC/Pvt/1026	Issue Date	26/03/2024			
UTR No.	U1659790512393015	Page No.	01			
Customer Details						
Office Name & Address	M/s YASH GLOBAL SCHOOL					
Ref. Letter No. & Date	YGS/APP/26-03-24					
Basic details of sample						
District	Aligarh	Block	Chandaus			
Gram Panchayat	Sabalpur	Village / NPP	Sabalpur			
Habitation	-	Location	YASH GLOBAL SCHOOL, Sabalpur Pisawa (Aligarh) 202155			
Water Source	Summer, R O Water	Sample No.	01			
Quantity of Sample	1000ml	Date of Collection	15/03/2024			
Receiving Date	15/03/2024	Sample Collector	Shailendra Kumar Sharma			
Sample Depositor	Shailendra Kumar Sharma	Sampling Method	As per IS 3025: Part 1:1986			
Analysis Start Date	15/03/2024	Analysis Completion Date	16/03/2024			
Technical Data of Analysis						
S. No.	Analyzed Parameters	Unit of Measurement	Observed Value	Specified Values as per BIS		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit	
1	2	3	4	5	6	7
1	pH	-	7.14	6.5 - 8.5	6.5 - 8.5	IS 3025 (PART 11) 2022 (ELECTROMETRIC METHOD)
2	Turbidity	NTU	0.73	1	5	IS 3025 (PT 10) 2017
3	TDS	mg/L	122	500	2000	IS 3025 (PT 16) 2017
4	Fluoride	mg/L	0.09	1	1.5	APHA 23 RD EDITION 4500-F METHOD C (ELECTRODE METHOD) 2017
5	Total Hardness	mg/L	76	200	600	IS 3025 (PART 21) 2019
6	Total Alkalinity	mg/L	92	200	600	IS 3025 (PART 23) 2019
7	chloride	mg/L	16	250	1000	IS 3025 (PART 32) 2019
8	Iron	mg/L	0.02	1	1	APHA 23 RD EDITION 3500-Fe METHOD B (Phenanthroline METHOD) 2017
9	Sulphate	mg/L	3.9	200	400	APHA 23 RD Edition 4500 SCM Method E Turbidly Method) 2017
10	Calcium	mg/L	12.8	75	200	IS 3025 (Part 40) 2019
11	Magnesium	mg/L	10.7	30	100	IS 3025(Part 40) 2019
12	Color (Hazen)	-	1	5	15	APHA 23 rd Edition Color 2120 B (Visual Comparison Mehtod)
13	Odour	-	Agreeable	-	-	IS 3025 (Part 05) 2018
14	E-Coli.	CFU	0	-	-	APHA 23 rd Edition 2017
15	Total Coliform	CFU	0	-	-	APHA 23 rd Edition 2017
16	Free Residual Chlorine	mg/L	0	0.5	0.5	IS 3025 (Part 26) 2021

Note

- 1- This certificate refers only to the samples submitted for testing
- 2- This certificate shall not be reproduced except in full, unless written permission for the publication of an unapproved abstract.
- 3- The test result reported in this certificate is valid at the time of and under the studied conclusion of measurements.
- 4- Sample will be stored up to 10 days (in case of non-perishable items only) from the date of issue of test reports.
- 5- Remark - Parameters above permissible limits are written in Bold.

Tested By

Yashwant Singh

(Deputy Technical Manager)



Office of the chief medical officer

Sanitation And Drinking Water Certificate

Letter No.CMO/Epi/OT/Sani,/2023-24/

Date-25-06-2023

It is certified that, Request Letter dated -15-06-2023 in which principal **Yash Global School Sabalpur Pisawa Aligarh** on the basis of her request to want a Certificate of Sanitation And Drinking Water Certificate. For above purpose the inspection team headed by Dr.Neeraj Tyagi MOIC Epidemic Cell CMO Office Aligarh and Jalkal Vibhag Nagar Nigam Aligarh, inspected on 20-06-2023 and found that the **Yash Global School Sabalpur Pisawa Aligarh** has safe drinking water facilities of the basis of the report of the Aligarh Jalkal Vibhag Laboratory (Attached Chemical Analysis of water Certificate) Nagar Nigam Aligarh for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/state Govt.

The Above certificate will be valid till 20.06.2024

Chief Medical Officer

